

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Taiwan Surface Mounting Technology (SuZhou) Co., Ltd. No. 888 Ganquan Dong Road Economic Technology Development Zone Wujiang, 215200 Suzhou China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	<p>CertaDrive 25W/m 0.6A 42V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,135 A; Pn: 29 W; PF: 0,9C; Uout: 30-42 Vdc; Uout max=60 Vdc; Iout: 0,6 A; Pout: 25 W; tc: 80 °C; Independent; SELV</p> <p>CertaDrive 30W/m 0.7A 42V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,15 A; Pn: 33 W; PF: 0,9C; Uout: 30-42 Vdc; Uout max=60 Vdc; Iout: 0,7 A; Pout: 30 W; tc: 80 °C; Independent; SELV</p> <p>CertaDrive 34W/m 0.8A 42V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,175 A; Pn: 38 W; PF: 0,9C; Uout: 30-42 Vdc; Uout max=60 Vdc; Iout: 0,8 A; Pout: 34 W; tc: 80 °C; Independent; SELV</p> <p>CertaDrive 40W/m 0.9A 44V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,2 A; Pn: 44 W; PF: 0,9C; Uout: 30-44 Vdc; Uout max=60 Vdc; Iout: 0,9 A; Pout: 40 W; tc: 80 °C; Independent; SELV</p> <p>CertaDrive 41W/m 1.05A 39V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,21 A; Pn: 46 W; PF: 0,9C; Uout: 27-39 Vdc; Uout max=60 Vdc; Iout: 1,05 A; Pout: 41 W; tc: 80 °C; Independent; SELV</p> <p>CertaDrive 21W/m 0.5A 42V 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,11 A; Pn: 24 W; PF: 0,9C; Uout: 30-42 Vdc; Uout max=60 Vdc; Iout: 0,5 A; Pout: 21 W; tc: 80 °C; Independent; SELV</p>

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



*Kreny Lin*

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	CertaDrive 25W/m 0.6A 42V 230V CertaDrive 30W/m 0.7A 42V 230V CertaDrive 34W/m 0.8A 42V 230V CertaDrive 40W/m 0.9A 44V 230V CertaDrive 41W/m 1.05A 39V 230V CertaDrive 21W/m 0.5A 42V 230V
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6028793.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**Additional factory**

Hengdian Group Tospo Lighting Co., Ltd.  
Hengdian Industrial Zone, 322118, Dongyang City, Jinhua, Zhejiang Province  
China

Dongyang Tospo Lighting Optoelectronic Co., Ltd.  
NO.5 NO.8 workshop, NO.88 Kexing Road, Hengdian Dongyang City,  
Zhejiang Province  
China


This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-05-07

Signature: Kreny Lin



page 3 of 3