



中国国家强制性产品认证证书

证书编号: 2017011002986601

委托人名称、地址

飞利浦照明(中国)投资有限公司

上海市闵行区田林路888弄9号楼

生产者(制造商)名称、地址

飞利浦照明(中国)投资有限公司

上海市闵行区田林路888弄9号楼

生产企业名称、地址

横店集团得邦照明股份有限公司

浙江省东阳市横店工业区工业大道183号

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,独立式,SELV,恒流模式,ta:55°C,Ⅰ类,IP66/IP67,适宜直接安装在普通可燃材料表面)

见附件。110-277V~50/60Hz

产品标准和技术要求

GB19510.14-2009;GB17625.1-2012;GB/T17743-2007;GB19510.1-200

9

上述产品符合强制性产品认证实施规则CNCA-C10-01:2014的要求,
特发此证。

发证日期:2017年07月19日 有效期至:2022年07月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。


本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2017011002986601

纸 号：

| 型号 | 输出电流 | 最大输出电压 | 输出功率 | tc值 |
|--------------------------------|------|------------|------|------|
| Xitanium 40W 0.70A TWE I160 | 0.7A | Max. 80Vdc | 40W | 80°C |
| Xitanium 25W 0.70A TWE I160 | 0.7A | Max. 50Vdc | 25W | 75°C |

输入：110-277V~ 50/60Hz

注：此附录与证书同时使用时有效。



主 任：

中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017011002986601

NAME AND ADDRESS OF THE APPLICANT

Philips Lighting (China) Investment Co., Ltd.
Building 9, Lane 888, Tianlin Road, Minhang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Philips Lighting (China) Investment Co., Ltd.
Building 9, Lane 888, Tianlin Road, Minhang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Hengdian Group Tospo Lighting Co., Ltd.
No.183 Industrial Avenue, Hengdian Industrial Zone, Dongyang City, Zhejiang Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgears For LED Modules (LED Driver,
Independent, SELV, Constant Current Mode, ta:55°C, Class I, IP66/IP67,
Suitable For Direct Mounting On Normally Flammable Material)

See Appendix. 110-277V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009;GB17625.1-2012;GB/T17743-2007;GB19510.1-2009


This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Jul.19,2017

Valid until: Jul.19,2022

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 1 页 共 1 页


证书编号: 2017011002986601

纸 号:

| 型号 | 输出电流 | 最大输出电压 | 输出功率 | tc值 |
|--------------------------------|------|------------|------|-----|
| Xitanium 40W 0.70A TWE I160 | 0.7A | Max. 80Vdc | 40W | 80℃ |
| Xitanium 25W 0.70A TWE I160 | 0.7A | Max. 50Vdc | 25W | 75℃ |

输入: 110-277V~ 50/60Hz

注: 此附录与证书同时使用时有效。



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE