

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED drivers
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Hengdian Group Tospo Lighting Co., Ltd. Hengdian Industrial Zone, 322118 Dongyang City, Jinhua, Zhejiang Province China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Xitanium 40W 0.7A TWE I160 Un: 110-277 V; lin: 0,42-0,18 Aac; fn: 50/60 Hz; PF: 0,9C; Pout: 40 W; Uout: 35-57 Vdc, 80 Vmax; Iout: 0,7 A; ta: -40..+ 55 °C; tc: 80 °C; independent; IP66/67 Xitanium 25W 0.7A TWE I160 Un: 110-277 V; lin: 0,27-0,12 Aac; fn: 50/60 Hz; PF: 0,9C; Pout: 25 W; Uout: 20-36 Vdc, 50 Vmax; Iout: 0,7 A; ta: -40..+ 55 °C; tc: 75 °C; independent; IP66/67
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 25W 0.7A TWE I160 Xitanium 40W 0.7A TWE I160
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	6005867.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands


