

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

LED driver

Name and address of the Applicant
Nom et adresse du demandeur

Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven
The Netherlands

Name and address of the manufacturer
Nom et adresse du fabricant

Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven
The Netherlands

Name and address of the factory
Nom et adresse de l'usine

Philips Lighting Poland S.A.
ul. Przemysłowa 29
64-290 Pila
Poland

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2016-05-27

Signature: Wim Singewald



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

Rating and principal characteristics

Valeurs nominales et caractéristiques principales

Xi LP150W 0.2-0.7A SN 230V S240 sXt:

Pin:162W; Uin: 220-240 V; Iin: 0,79-0,65 A; Freq: 50/60 Hz; PF: 0,95;
Pout:150W; Uout: 90-283V; Iout: 200-700 mA;
ta: -40...+55 °C; tc(max): 90 °C, Uout max=340V

Xi LP 150W 0.2-0.7A S1 230V S240 sXt:

Pin:162W; Uin: 220-240 V; Iin: 0,79-0,65 A; Freq: 50/60 Hz; PF: 0,95;
Pout:150W; Uout: 90-283V; Iout: 200-700 mA;
ta: -40...+55 °C; tc(max): 90 °C, Uout max=340V

Xi LP 150W 0.2-0.7A SL 230V S240 sXt

Pin:162W; Uin: 220-240 V; Iin: 0,79-0,65 A; Freq: 50/60 Hz; PF: 0,95;
Pout:150W; Uout: 90-283V; Iout: 200-700 mA;
ta: -40...+55 °C; tc(max): 90 °C, Uout max=340V

Xi LP 150W 0.3-1.0A S1 230V S240 sXt

Pin:162W; Uin: 220-240 V; Iin: 0,79-0,65 A; Freq: 50/60 Hz; PF: 0,95;
Pout:150W; Uout: 70-214V; Iout: 300-1050 mA;
ta: -40...+55 °C; tc(max): 90 °C, Uout max=260V

Xi LP 150W 0.3-1.0A SL 230V S240 sXt

Pin:162W; Uin: 220-240 V; Iin: 0,79-0,65 A; Freq: 50/60 Hz; PF: 0,95;
Pout:150W; Uout: 70-214V; Iout: 300-1050 mA;
ta: -40...+55 °C; tc(max): 90 °C, Uout max=260V

Xi LP 75W 0.2-0.7A SN 230V S240 sXt:

Pin:82W; Uin: 220-240 V; Iin: 0,42-0,33 A; Freq: 50/60 Hz; PF: 0,95; Pout:75W;
Uout: 50-150V; Iout: 200-700 mA; ta: -40...+55 °C; tc(max): 85 °C, Uout max=190V

Xi LP 75W 0.2-0.7A S1 230V S240 sXt:

Pin:82W; Uin: 220-240 V; Iin: 0,42-0,33 A; Freq: 50/60 Hz; PF: 0,95; Pout:75W;
Uout: 50-150V; Iout: 200-700 mA; ta: -40...+55 °C; tc(max): 85 °C, Uout max=190V

Xi LP 75W 0.2-0.7A SL 230V S240 sXt

Pin:82W; Uin: 220-240 V; Iin: 0,42-0,33 A; Freq: 50/60 Hz; PF: 0,95; Pout:75W;
Uout: 50-150V; Iout: 200-700 mA; ta: -40...+55 °C; tc(max): 85 °C, Uout max=190V

Xi LP 75W 0.3-1.0A S1 230V S240 sXt

Pin:82W; Uin: 220-240 V; Iin: 0,42-0,33 A; Freq: 50/60 Hz; PF: 0,95; Pout:75W;
Uout: 35-108V; Iout: 300-1050 mA; ta: -40...+55 °C; tc(max): 85 °C, Uout max=140V

Xi LP 75W 0.3-1.0A SL 230V S240 sXt

Pin:82W; Uin: 220-240 V; Iin: 0,42-0,33 A; Freq: 50/60 Hz; PF: 0,95; Pout:75W;
Uout: 35-108V; Iout: 300-1050 mA; ta: -40...+55 °C; tc(max): 85 °C, Uout max=140V

PHILIPS

Trademark (if any)

Marque de fabrique (si elle existe)

Type of manufacturer's Testing Laboratories used

Type de programme de laboratoire d'essais constructeur

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2016-05-27

Signature: Wim Singewald

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

Model / Type Ref.

Réf. de type

Xi LP150W 0.2-0.7A SN 230V S240 sXt
 Xi LP 150W 0.2-0.7A S1 230V S240 sXt
 Xi LP 150W 0.2-0.7A SL 230V S240 sXt
 Xi LP 150W 0.3-1.0A S1 230V S240 sXt
 Xi LP 150W 0.3-1.0A SL 230V S240 sXt
 Xi LP 75W 0.2-0.7A SN 230V S240 sXt
 Xi LP 75W 0.2-0.7A S1 230V S240 sXt
 Xi LP 75W 0.2-0.7A SL 230V S240 sXt
 Xi LP 75W 0.3-1.0A S1 230V S240 sXt
 Xi LP 75W 0.3-1.0A SL 230V S240 sXt

Additional information (if necessary may also be reported on
page 2)

Les informations complémentaires (si nécessaire, peuvent être
indiquées sur la 2ème page)

A sample of product was tested and found to be in conformity
with IEC

Un échantillon de ce produit a été essayé et été considéré
conforme à la CEI

National differences / Comments

Les différences nationales / Commentaires

As shown in the test report Ref. No. which forms part of this
certificate

Comme indiqué dans le rapport d'essais numéro de référence
qui constitue partie de ce certificat

61347-1(ed.2);am1;am2

61347-2-13(ed.2)

62384(ed.1);am1

EU Group Differences

2193426.50, 2193426.51

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2016-05-27

Signature: Wim Singewald

A handwritten signature in blue ink, appearing to be "Wim Singewald", written over a circular blue stamp or seal.

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

Additional factory

Taiwan Surface Mounting Technology (SuZhou) Co., Ltd.
No. 888 GanQuan Dong Road Economic Technology Development Zone
WuJiang, Jiangsu Province
China

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2016-05-27

Signature: Wim Singewald

