

CERTIFICATE

Issued to:
Applicant:
Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven
The Netherlands

Manufacturer/Licensee:
Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven
The Netherlands

Product : EasySense Fixture-Mount Sensor
Trade name : PHILIPS
Product key : SNSX0Y (see additional information for more details)

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015; EN 61347-2-11:2001
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

DEKRA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on 20 July 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2195751.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Ted Drost
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	EasySense Luminaire-Mount Sensor
trade name	:	PHILIPS
product key	:	SNSX0Y (see additional information for more details)
input voltage	:	16-22 Vdc
ambient temperature ranges (ta)	:	0...+50 °C
max. case temperature (tc)	:	+55 °C

Additional information**Product key:**

SNSX0Y

SNS = Product name

X = Function (can be replaced by 1, 2, 3, 4)

1 = Stand alone

2 = Advanced grouping

3 = Networked

4 = Sensic

0 = No meaning, always a 0

Y = Function (can be replaced by 1, 2, 3)

1 = Basic

2 = With zigbee green power switch

3 = With defond switch

Sensor is power by a SR driver with a (FELV) voltage of 16-22 V and should have at least basic insulation towards mains.

TESTS**Test requirements**

EN 61347-1:2015

EN 61347-2-11:2001

Test result

The test results are laid down in DEKRA test file 2195751.00.

Remarks

-For component list refers to annex 1 of the test reports 2195751.50

-This certificate supersedes certificate no. 2192470.01, dated on 12 April 2016 which is herewith declared invalid.

Conclusion


The examination proved that all test requirements were met.

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF3).

Supervised by : T.H.J.M. Michels

A handwritten signature in blue ink, appearing to read "Michels", written over a horizontal line.

Checked by : H.J.H. te Lindert

A handwritten signature in blue ink, appearing to read "H.J.H. te Lindert", written over a horizontal line.