

CERTIFICATE

Number: **2139864.01**

Issued to:
Applicant:
Philips Lighting B.V.
GBU LED Lamps and Systems
Mathildelaan 1
5611 BD, Eindhoven, The Netherlands



Manufacturer/Licensee:
Philips Lighting B.V.
BG Lighting Electronics
Mathildelaan 1
5611 BD, Eindhoven, The Netherlands

Product : Electronic driver for LED modules
Trade name : PHILIPS
Types : XITANIUM 17W 0,3-0,7A 24V 230V PCB,
XITANIUM 17W 0,3-0,7A 24V TE/I 230,
XITANIUM 25W 0,3-0,7A 36V TE/I 230

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA Quality hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2008; EN 61347-2-13:2006; EN 62384:2006
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

KEMA Quality hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: November 5, 2010 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

T.M.H. Huët
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed