

CERTIFICATE

Issued to:
Applicant:
Philips (China) Investment Co., Ltd.
#9, Lane 888, Tianlin Road
200233 Shanghai, China

Manufacturer/Licensee:
Philips (China) Investment Co., Ltd.
#9, Lane 888, Tianlin Road
200233 Shanghai, China

Product : LED driver
Trade name : PHILIPS
Types : Xitanium Dim 75W 0.70A 1-10V TWE I175
Xitanium 75W 0.70A TWE I175

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2008; EN 61347-2-13:2014; EN 62384:2006
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2101376

DEKRA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.


This certificate is issued on: 20 August 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2185119.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



A.P. van der Veen
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: LED driver
trade name	: PHILIPS
types	: Xitanium 75W 0.70A TWE I175, Xitanium Dim 75W 0.70A 1-10V TWE I
rated voltage	: 110-277 V
nature of supply	: ac
rated frequency	: 50/60 Hz
power factor	: 0,98
input current	: 0,32-0,82 A
output current	: 0,7 Adc
output voltage	: 40-117 Vdc
Uout (max open circuit)	: 200 Vdc
max. case temperature (tc)	: 80 °C
ambient temperature range (ta)	: -40...+55 °C
degree of protection	: IP66 or IP67
description	: independent

Additional information

The insulation between primary and secondary is considered as basic insulation.
LED drivers are completely potted with PUR.

TESTS**Test requirements**

Main test requirements:
EN 61347-1:2008 + A1:2011 + A2:2013
EN 61347-2-13:2014
EN 62384:2006 + A1:2009

Additional test requirements:
EN 60598-1:2015

Test result

The test results are laid down in DEKRA test file 2185119.00.

Remarks

For component list refers to annex 1 of test reports 2185119.50
This certificate is issued to supersede the original ENEC certificate 2182846.01 dated 2015-06-24.

Conclusion

The examination proved that all test requirements were met.

Tested by : J.G.H. Gelink

A handwritten signature in blue ink, appearing to be 'J.G.H. Gelink', written over a horizontal line.

Checked by : Theo Michels

A handwritten signature in blue ink, appearing to be 'Theo Michels', written over a horizontal line.

Factory location(s)

Taiwan Surface Mounting, Technology (SuZhou) Co., Ltd.
No. 888 Ganquan Dong Road,
Economic Technology Development Zone
215200 Wujiang Jiangsu Province
China