

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED drivers
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Taiwan Surface Mounting Technology (SuZhou) Co., Ltd. No. 888, Ganquan Dong Road, Economic Technology Development Zone, WuJiang, Suzhou China
Ratings and principal characteristics	Xitanium 150W 0.70A TWE I220 Un: 110-277 V; Iin: 1,5-0,65 Aac; fn: 50/60 Hz; PF: 0,95; Pout: 150 W; Uout: 90-214 Vdc, 320 Vmax; Iout: 0,7 A; ta: -40..+ 55 °C; tc: 85 °C; independent; IP66/67  Xitanium Dim 150W 0.70A 1-10V TWE I220 Un: 110-277 V; Iin: 1,5-0,65 Aac; fn: 50/60 Hz; PF: 0,95; Pout: 150 W; Uout: 90-214 Vdc, 320 Vmax; Iout: 0,7 A; ta: -40..+ 55 °C; tc: 85 °C; independent; IP66/67  Xitanium Dim 150W 0.7A 1-10V TWE I220C Un: 110-277 V; Iin: 1,5-0,65 Aac; fn: 50/60 Hz; PF: 0,95; Pout: 150 W; Uout: 90-214 Vdc, 320 Vmax; Iout: 0,7 A; ta: -40..+ 55 °C; tc: 85 °C; independent; IP66/67
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 150W 0.70A TWE I220 Xitanium Dim 150W 0.70A 1-10V TWE I220 Xitanium Dim 150W 0.7A 1-10V TWE I220C
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	6010005.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2017-06-23

Signature: Kreny Lin

page 1 of 1