

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 <div style="background-color: black; width: 100px; height: 40px;"></div>
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	<p>Xitanium 60W 0.08-0.35A 300V S/16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 60 W; Uout: 100-300 Vdc; Uout max = 330 V; tc: 75 °C; ta: -25...+50 °C; Built-in</p> <p>Xitanium 60W 0.08-0.35A 220V S/16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 60 W; Uout: 50-220 Vdc; Uout max = 250 V; tc: 75 °C; ta: -25...+50 °C; Built-in</p> <p>Xitanium 35W 0.08-0.35A 150V S/16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,17 A; Pn: 39 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 35 W; Uout: 50-150 Vdc; Uout max = 250 V; tc: 75 °C; ta: -25...+50 °C; Built-in</p>
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	<p>Xitanium 60W 0.08-0.35A 300V S/16 230V</p> <p>Xitanium 60W 0.08-0.35A 220V S/16 230V</p> <p>Xitanium 35W 0.08-0.35A 150V S/16 230V</p>
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	<p>IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016</p> <p>National differences:</p> <p>EU Group Differences</p>

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2017-05-18

Signature: Kreny Lin

Kreny

page 1 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No. which
forms part of this Certificate

6008303.50


This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory



This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2017-05-18

Signature: Kreny Lin

A handwritten signature in black ink, appearing to read "Kreny Lin".

page 3 of 3