


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic driver for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	<p>Xitanium 35W 0.08-0.35A 220V TD16 230V Un: 220 - 240 V In: 0.18 A Pn: 39 W fn: 50/60 Hz; DC PF: 0.9C Uout max: 250 V ta: -25...+50 °C tc: 75 °C Uout: 50 - 220 Vdc Iout: 0.08-0.35 Adc Pout: 35 W</p> <p>Xitanium 60W 0.08-0.35A 300V TD16 230V Un: 220 - 240 V In: 0.30 A Pn: 66 W fn: 50/60 Hz; DC PF: 0.9C Uout max: 330 V ta: -25...+50 °C tc: 75 °C Uout: 100 - 300 Vdc Iout: 0.08-0.35 Adc Pout: 60 W</p> <p>Xitanium 60W 0.15-0.5A 220V TD16 230V Un: 220 - 240 V In: 0.30 A Pn: 66 W fn: 50/60 Hz; DC PF: 0.9C Uout max: 250 V ta: -25...+50 °C tc: 75 °C Uout: 50 - 220 Vdc Iout: 0.15-0.5 Adc Pout: 60 W</p>
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 35W 0.08-0.35A 220V TD16 230V Xitanium 60W 0.08-0.35A 300V TD16 230V Xitanium 60W 0.15-0.5A 220V TD16 230V
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**

A sample of the product was tested and found
to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC
62384:2006/AMD1:2009

National differences:

EU Group Differences, AS, NZ

2236390.50 and 2236390.51

As shown in the Test Report Ref. No. which
forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-04-24

Signature: Anouschka Slingerland

page 2 of 3

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-04-24

Signature: Anouschka Slingerland



page 3 of 3