

PHILIPS

Sensors

EasyAir

PTM215ZE EnOcean
module



Switch Commissioning Procedure

Switch Commissioning Procedure for PTM215ZE EnOcean module




Figure 1 - Outer appearance of PTM215ZE module

This switch contains a PTM215ZE EnOcean module internally as shown in the figure below. For commissioning this switch into a group, the cover need not be removed and you may choose to work with any one of the buttons on the switch.

To add such a switch to a group, ensure that the group is open. Opening of a ZigBee group is possible using EasyAir IR app with either **“Create group”** or **“Add to Group”** options. Once the group is open, follow the steps given below:

1. Long press - Press and hold the chosen button* for 10 seconds
 2. Short press - Press and hold the button* for 1 second
 3. Long press - Press and hold the button* for 10 seconds
 4. Now, perform a series of short presses of 1 second each with the button* until the luminaires blink. This should be done upto a maximum of 16 times and in one of the 16 presses, the channel will coincide with the luminaires and a feedback will be received.
 5. After getting the luminaire feedback, complete the commissioning procedure by making a short press with any of the **other** buttons.
 6. Close the group using EasyAir IR app with **“Close group”** option.
- Now the switch is successfully commissioned and added to the group.

* Irrespective of whether it is single rocker or a dual rocker switch, choose to work with any one of the buttons. However, the same button should be used in case of re-commissioning the switch.

Note: The above procedure also holds for ZigBee channel change. If you change the channel using the IR app, then you have to perform the switch commissioning procedure again.



© 2019 Signify Holding. All rights reserved. The information provided herein is subject to change, without notice. Signify does not give any representation or warranty as to the accuracy or completeness of the information included herein and shall not be liable for any action in reliance thereon. The information presented in this document is not intended as any commercial offer and does not form part of any quotation or contract, unless otherwise agreed by Signify.

www.lighting.philips.co.uk/oem-emea/products/connected-lighting

Philips and the Philips Shield Emblem are registered trademarks of Koninklijke Philips N.V. All other trademarks are owned by Signify Holding or their respective owners.

03/2019
Data subject to change