

# CERTIFICATE

Issued to:  
Applicant:  
**Signify Netherlands B.V.**  
**High Tech Campus 48**  
**5656 AE Eindhoven, The Netherlands**

Licensee:  
**Signify Netherlands B.V.**  
**High Tech Campus 48**  
**5656 AE Eindhoven, The Netherlands**

Product : LED driver  
Trade name(s) : PHILIPS  
Type(s)/model(s) : XiFP 330W 2:0.2-0.75A SNDAE 230V C240 sXt

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 8 August 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-109755

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



K Xu  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: LED driver
Trade name(s)	: PHILIPS
Type(s)/model(s)	: XiFP 330W 2:0.2-0.75A SNDAE 230V C240 sXt
Rated voltage	: 220-240 Vac or 186-250 Vdc
Rated frequency	: 50/60 Hz at AC
Power factor	: 0,95
Rated input current	: 1,64-1,48 Aac or 1,12 Adc
Rated input power	: 356 W
Rated output voltage	: 100-300 V; 350 V max. open-circuit
Rated output current	: 200-750 mA
Output power	: 330 W
Max. case temperature (tc)	: 90 °C
Ambient temperature (ta)	: -40 °C...+55 °C
Temperature declared thermally protection	: 130 °C
Description	: Built-in with double/reinforced insulation

**TESTS****Test requirements**

EN 61347-1:2015  
EN 61347-2-13:2014  
EN 61347-2-13:2014/A1:2017  
EN 62384:2006  
EN 62384:2006/A1:2009

**Test result**

The test results are laid down in DEKRA test file 605982900.

**Additional information**

constant current type with screwless terminal block  
LED driver is completely potted with asphalt  
Double/reinforced insulation between PRI and SEC  
Suitable for emergency lighting excluding high risk task areas

For component list refers to annex 1 of test reports 6059829.50.

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

This certificate replaces certificate No. 31-103597 which we herewith declare invalid.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

The factory location is registered with the number 674666.