

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**
CB TEST CERTIFICATE

Product

Independent LED Controlgear

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the manufacturer




Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Input: 220-240 V~ 50/60 Hz 0.53 A~
186-250 V  0.62-0.47 A  λ :0.95
Output: 24 V  4.17 A max. 100 W max.
 t_a = -20...50°C, t_c = 85°C max.

Class II, SELV



Trademark / Brand (if any)

PHILIPS

Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LED Transformer 100W 24VDC TD 220-240V

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 61347-2-13:2014/A1:2017 and EN 61347-1: 2015.

National Differences specified in the CB Test Report.

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015/AMD1:2017, IEC 61347-1:2015,
IEC 61347-2-13:2014/AMD1:2016, IEC 61347-2-13:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

4789529218.1 issued on 2020-08-25

This CB Test Certificate is issued by the National Certification Body


UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2020-08-25

Signature:

Jan-Erik Storgaard