

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**
CB TEST CERTIFICATE

Product

Independent LED Controlgear

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Input: 220-240 V~ 50/60 Hz 0.79 A~
186-250 V== 0.9-0.67 A== λ:0.95
Output: 24 V== 6.25 A max. 150 W max.
ta= -20...50°C, tc= 85°C max.

Class II, SELV 

Trademark / Brand (if any)

PHILIPS

Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LED Transformer 150W 24VDC TD 220-240V

Additional information (if necessary may also be reported on page 2)

The report was revised to include technical modifications.

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015/AMD1:2017, IEC 61347-1:2015, IEC 61347-2-13:2014/AMD1:2016, IEC 61347-2-13:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

4789529203.1 Amendment 1 issued on 2020-08-11

This CB Test Certificate is issued by the National Certification Body



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2020-08-11

Original Issue Date: 2020-08-04

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-100855-M1-UL

Additional Information:

Additionally evaluated to EN 61347-2-13:2014/A1:2017 and EN 61347-1: 2015.

National Differences specified in the CB Test Report.

The original report was modified to include the following changes/additions:

1. Revise Australian/New Zealand National Differences in Enclosure 1 to cover AS/NZS 61347.1: 2016/Amd 1: 2018 & AS/NZS 61347.2.13: 2018.
2. Update ratings.

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2020-08-11

Original Issue Date: 2020-08-04

Signature:

Jan-Erik Storgaard