



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-201810-EA

Certificate Holder: Signify (China) Investment Co., Ltd.
Building No. 9, Lane 888, Tianlin Road,
Minhang,
200233 Shanghai
P.R. China

Regulatory Definition: Power Supply or Charger
Product Description: Electronic controlgear for LED modules
(LED driver, independent, SELV,
constant voltage, Non- IC)
Trade Name: PHILIPS
Model No.: CertaDrive LED Transformer 250W 24VDC
Rating/Marking: Input: 220-240V~ 50/60Hz 1.5A
Output: 24Vdc 250W
ta: 45°C tc: 90°C, Class II

Standard: AS 61347.2.13:2018
AS/NZS 61347.1:2016 Inc A1

Conditions: Nil

Approval Mark: RCM and SAA-201810-EA

Date First Registered: 27 July 2020
Date of Expiry: 27 July 2025


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 27-07-20 201810/1



A P P R O V A L S ®

Certificate of Conformity

Addendum

Certificate No.: SAA-201810-EA

Date of Issue: 27 July 2020

Regulatory Definition: Power Supply or Charger
Product Description: Electronic controlgear for LED modules
(LED driver, independent, SELV,
constant voltage, Non- IC)

Additional Models	Trade Name	Rating/Marking
Xi LED Transformer 250W 1-10V 24VDC	PHILIPS	Input: 220-240V~ 50/60Hz 1.5A Output: 24Vdc 250W ta: 45°C tc: 90°C, Class II
Xi LED Transformer 30W 1-10V 24VDC	PHILIPS	Input: 220-240V~ 50/60Hz 0.19A Output: 24Vdc 30W ta: 45°C tc: 80°C, Class II
Xi LED Transformer 60W 1-10V 24VDC	PHILIPS	Input: 220-240V~ 50/60Hz 0.35A Output: 24Vdc 60W ta: 45°C tc: 80°C, Class II
Xi LED Transformer 100W 1-10V 24VDC	PHILIPS	Input: 220-240V~ 50/60Hz 0.6A Output: 24Vdc 100W ta: 45°C tc: 90°C, Class II
Xi LED Transformer 150W 1-10V 24VDC	PHILIPS	Input: 220-240V~ 50/60Hz 0.9A Output: 24Vdc 150W ta: 45°C tc: 90°C, Class II

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 27-07-20 201810/2