

AUSTRALIA & NEW ZEALAND CERTIFICATE OF SUITABILITY

Certificate No. ULL-101344
Page 1/3
Date of Issue 2018-11-20

Certificate Holder Philips Lighting B.V.
 High Tech Campus 45, 5656 AE Eindhoven, The Netherlands

Certified Product Description

LED Driver

{non-isolating component for building in}

Model(s) Xitanium 100W 0.25-0.7A 220V S 230V

Trade Name or Trademark PHILIPS

Rating Information (input) 220-240 Vac, 0.47 A max, 50/60 Hz
 (output) 50-220 Vdc , 0.25-0.7 A, 100 W

Risk Class Level 1

Standard to which Certification Declared AS/NZS IEC 61347.2.13:2013,
 AS/NZS 61347.1:2016

Test Facility/Facilities and Test Standards UL-CCIC Company Limited, Suzhou, China , IEC 61347-2-13:2014,
 A1:2016/IEC 61347-1:2015 , AS/NZS IEC 61347.2.13:2013/AS/NZS
 61347.1:2016

Certification Marking RCM mark only in accordance with the details on page 3

Additional Information and Conditions This certificate is issued by UL under the Queensland Electrical Safety
 Office administered Recognised External Certification Scheme, in
 accordance with the requirements of the Australian Electrical Equipment
 Safety System.


See also Page 2

Expiry date 2023-11-20



Stuart Foster
 Certification Officer

JAS-ANZ



www.jas-anz.org/register

Certification Body

This is to certify that representative samples of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate. This certificate is issued in accordance with a) the contractual agreement between UL and the certificate holder, b) the ANZ Certification Program Terms and Conditions, c) JAS-ANZ accreditation requirements and d) any further scheme or arrangement for which compliance is noted in "Additional Information and Conditions" above. It is based on type assessment of representative product(s) and is issued for use in Australia and New Zealand only.

This Certificate remains the property of UL International New Zealand Ltd.

Equipment covered by this approval must comply in all respects with the certified article and, unless the appendix to this certificate indicates marking is either voluntary or prohibited, is required to be clearly and indelibly marked with the marking indicated in the appendix. The certificate holder must immediately notify UL International New Zealand Ltd if these conditions are not met.

Notification must be made to UL International New Zealand Ltd within 20 working days of any modification to the product, change of manufacturer or change of certificate holder details.

If the client provides copies of the certification documents to others, the documents shall be reproduced in their entirety.

This approval shall expire on the date indicated above unless the certificate is suspended, cancelled or withdrawn for any reason prior to that date.

All dates are in Year-Month-Day format (YYYY-MM-DD).

UL International New Zealand Ltd,
 21 Tarndale Grove, Albany,
 Auckland 0632, New Zealand.
 +64 9 415 3355, customerservice.anz@ul.com,
<http://newzealand.ul.com>



APPENDIX - AUSTRALIA AND NEW ZEALAND CERTIFICATE OF SUITABILITY

Certificate No.	ULL-101344
Page	2/3
Date of Issue	2018-11-20

Additional Information: Component does not provide an isolated output. It is intended for building in to a luminaire and luminaire provides the protection from access to live parts.

Certification Body

UL International New Zealand Ltd,
21 Tarnedale Grove, Albany,
Auckland 0632, New Zealand.
+64 9 415 3355, customerservice.anz@ul.com,
<http://newzealand.ul.com>



APPENDIX - AUSTRALIA AND NEW ZEALAND CERTIFICATE OF SUITABILITY

Certificate No.	ULL-101344
Page	3/3
Date of Issue	2018-11-20

The Regulatory Compliance Mark (RCM), in which case all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.



Certification Body

UL International New Zealand Ltd,
21 Tarndale Grove, Albany,
Auckland 0632, New Zealand.
+64 9 415 3355, customerservice.anz@ul.com,
<http://newzealand.ul.com>

