

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Product : LED Driver
Trade name(s) : PHILIPS
Type(s)/model(s) : Xitanium 100W 0.25-0.7A 220V S 230V

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 27 April 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-113592

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED Driver
Trade name(s)	: PHILIPS
Type(s)/model(s)	: Xitanium 100W 0.25-0.7A 220V S 230V
Rated voltage	: 220-240 Vac/Vdc
Rated frequency	: 50/60 Hz at ac
Power factor	: 0,9C
Max. case temperature (tc)	: 75 °C
Ambient temperature (ta)	: -25...+50 °C
Temperature declared thermally protection	: 110 °C
Output current	: 0,25-0,7 A
Output voltage	: 50-220 Vdc, 250 Vdc max.
Description	: Built-in

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009

Test result

The test results are laid down in DEKRA test file 607682800.

Additional information

constant current type with screwless terminal block
no insulation between primary and secondary
suitable for emergency luminaire acc. 60598-2-22 excluding high-risk task area

For component list refers to annex 1 of test reports 6076828.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory locations are registered with the numbers 674666, 305810, 306303 and 15204.