

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Electronic driver for LED modules

Name and address of the applicant

Signify Netherlands B.V.  
High Tech Campus 48  
5656 AE Eindhoven  
The Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.  
High Tech Campus 48  
5656 AE Eindhoven  
The Netherlands

Name and address of the factory

☒ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Xitanium 35W 0.08-0.35A 220V TD16 230V  
Un: 220 - 240 V In: 0.18 A Pn: 39 W  
fn: 50/60 Hz; DC PF: 0.9C  
Uout max: 250 V ta: -25...+50 °C tc: 75 °C  
Uout: 50 - 220 Vdc Iout: 0.08-0.35 Adc Pout: 35 WXitanium 60W 0.08-0.35A 300V TD16 230V  
Un: 220 - 240 V In: 0.30 A Pn: 66 W  
fn: 50/60 Hz; DC PF: 0.9C  
Uout max: 330 V ta: -25...+50 °C tc: 75 °C  
Uout: 100 - 300 Vdc Iout: 0.08-0.35 Adc Pout: 60 WXitanium 60W 0.15-0.5A 220V TD16 230V  
Un: 220 - 240 V In: 0.30 A Pn: 66 W  
fn: 50/60 Hz; DC PF: 0.9C  
Uout max: 250 V ta: -25...+50 °C tc: 75 °C  
Uout: 50 - 220 Vdc Iout: 0.15-0.5 Adc Pout: 60 W

Trademark (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium 35W 0.08-0.35A 220V TD16 230V  
Xitanium 60W 0.08-0.35A 300V TD16 230V  
Xitanium 60W 0.15-0.5A 220V TD16 230V

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

A sample of the product was tested and found  
to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC  
62384:2006/AMD1:2009

National differences:

EU Group Differences, AS, NZ

As shown in the Test Report Ref. No. which  
forms part of this Certificate

2236390.50 and 2236390.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-04-24

Signature: Anouschka Slingerland



page 2 of 3