

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

LED driver

Name and address of the applicant

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
Netherlands

Name and address of the factory

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Xitanium 41W 0.5-0.8A 51V DS 230V  
Uin: 220-240 Vac; Iin: 0,2 Aac; Freq: 50/60 Hz; Pin: 46 W; PF: 0,97;  
Output voltage: 23-51 Vdc; Uout: 60 Vdc;; Prated: 41 W;  
Iout: 0,5/0,6/0,7/0,8 A;  
ta: -20...+50 °C; tc: 75 °C; SELV; built-in;Xitanium 18W 0.2-0.35A 51V DS 230V  
Uin: 220-240 Vac; Iin: 0,1 Aac; Freq: 50/60 Hz; Pin: 21 W; PF: 0,97;  
Output voltage: 23-51 Vdc; Uout: 60 Vdc; Prated: 18 W;  
Iout: 0,2/0,25/0,3/0,35 A;  
ta: -20...+50 °C; tc: 75 °C; SELV; built-in

Trademark (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Xitanium 41W 0.5-0.8A 51V DS 230V  
Xitanium 18W 0.2-0.35A 51V DS 230V

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6130865.50 and 6130865.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands

Date: 2022-07-01

Signature: Kate Xu