

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Electronic driver for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 <div></div>
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Xitanium 150W 0.2-0.7A 300V iXt 230V: Un: 220 - 240 Vac; In: 0.73 A; Pn: 158 W Un: 186 - 250 Vac; fn: 50 / 60 Hz; DC; PF: 0.9C Uout: 100 - 300 V; Iout: 0.2 - 0.7 A; Pout = 150 W U-out max: 330 V; tc (max): 90 °C; ta: -40...+60 °C  Xitanium 100W 0.15-0.5A 300V iXt 230V: Un: 220 - 240 Vac; In: 0.49 A; Pn: 106 W Un: 186 - 250 Vac; fn: 50 / 60 Hz; DC; PF: 0.9C Uout: 100 - 300 V; Iout: 0.15 - 0.5 A; Pout = 100 W U-out max: 330 V; tc (max): 90 °C; ta: -40...+60 °C
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 150W 0.2-0.7A 300V iXt 230V Xitanium 100W 0.15-0.5A 300V iXt 230V
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces certificate no. NL-39388, dated on 2016-01-11 due to update of test standards
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009  National differences: EU Group Differences

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

As shown in the Test Report Ref. No. which  
forms part of this Certificate

2248197.72 and 2248197.73

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

