

CERTIFICATE

Issued to:
Applicant:
Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven, The Netherlands

Manufacturer/Licensee:
Philips Lighting B.V.
High Tech Campus 45
5656 AE Eindhoven, The Netherlands

Product : LED driver
Trade name(s) : PHILIPS
Type(s)/model(s) : Xitanium 50W 1.1/1.2A 42V | 230V, Xitanium 59W 1.3/1.4A 42V | 230V and
Xitanium 64W 1.5/1.6A 40V | 230V

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-2-13:2014, EN 61347-1:2015, EN 62384:2006, EN 62384:2006/A1:2009 and EN 60598-1:2015
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 21 November 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-102064

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED driver
Trade name(s)	: PHILIPS
Type(s)/model(s)	: Xitanium 50W 1.1/1.2A 42V I 230V, Xitanium 59W 1.3/1.4A 42V I 230V and Xitanium 64W 1.5/1.6A 40V I 230V
Rated input voltage	: 220-240
Nature of supply	: ac
Rated frequency	: 50/60 Hz
Case temperature (tc)	: 95 °C
Power factor (PF)	: 0,92C
Description	: Independent

Product data – type Xitanium 50W 1.1/1.2A 42V I 230V

Rated input current	: 0,27/0,25 A
Rated input power	: 58/54 W
Output current	: 1,20/1,10 A
Output voltage	: 30-42 Vdc; 60 Vdc Max
Output power	: 50/46,2 W

Product data – type Xitanium 59W 1.3/1.4A 42V I 230V

Rated input current	: 0,31/0,29 A
Rated input power	: 67/62 W
Output current	: 1,40/1,30 A
Output voltage	: 30-42 Vdc, 60 Vdc Max
Output power	: 59/54,6 W

Product data – type Xitanium 64W 1.5/1.6A 40V I 230V

Rated input current	: 0,35/0,32 A
Rated input power	: 73/68 W
Output current	: 1,60/1,50 A
Output voltage	: 30-40 Vdc, 60 Vdc Max
Output power	: 64/60 W

TESTS**Test requirements**

EN 61347-2-13:2014
EN 61347-1:2015
EN 62384:2006
EN 62384:2006/A1:2009
EN 60598-1:2015

Test result

The test results are laid down in DEKRA test file 602044600.

Additional information

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

The list of components is laid down at test report 6020446.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

Hengdian Group Tospo Lighting Co., Ltd.
No.88, Kexing Road Hengdian Electronics Industrial Zone
322118 Dongyang Zhejiang, China

Taiwan Surface Mounting Technology (SuZhou) Co., Ltd.
No. 888 GanQuan Dong Road Economic
Technology Development Zone WuJiang,
Suzhou, China