

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Product : LED panel luminaire (Suitable for suspension mounted or recessed mounted)
Trade name(s) : Signify
Type(s)/model(s) : Fortimo LED Panel 6060 830 MD2, Fortimo LED Panel 6060 840 MD2 and
Fortimo LED Panel 6060 865 MD2

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2015, EN 60598-2-1:1989 and EN 60598-2-2:2012
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2037471


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 14 February 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-107428

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



JMg Marggraf
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED panel luminaire (Suitable for suspension mounted or recessed mounted)
Trade name(s)	: Signify
Type(s)/model(s)	: Fortimo LED Panel 6060 830 MD2, Fortimo LED Panel 6060 840 MD2 and Fortimo LED Panel 6060 865 MD2
Rated input voltage	: 33-41 Vdc
Rated input current	: 1150 mA constant current
Max. power	: 38 W
Class of insulation	: Class III
Degree of protection	: IP20
Ambient temperature (ta)	: 45 °C
Description	: non-user replaceable LEDs; Not suitable for covering with thermally insulated material

TESTS**Test requirements**

EN 60598-1:2015
EN 60598-2-1:1989
EN 60598-2-2:2012

Test result

The test results are laid down in DEKRA test file 435132000.

Additional information

The list of components is laid down at test report 4351320.50.

Conclusion

The examination proved that all requirements were met.

Factory location