

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED panel luminaire (Suitable for suspension mounted or recessed mounted)

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
The Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
The Netherlands

Name and address of the factory

☐ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Class III, IP20, 33-41 Vdc, 1,15 A constant current, 38 W, ta:45 °C,
non-user replaceable LEDs;
Not suitable for covering with thermally insulated material;
Fortimo LED Panel 6060 830 MD2: 3000 K;
Fortimo LED Panel 6060 840 MD2: 4000 K;
Fortimo LED Panel 6060 865 MD2: 6500 K

Trademark (if any)

Signify

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Fortimo LED Panel 6060 830 MD2, Fortimo LED Panel 6060 840 MD2,
Fortimo LED Panel 6060 865 MD2

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-2-1:1979, IEC 60598-2-1:1979/AMD1:1987, IEC 60598-2-2:2011

National differences:

EU Group Differences, EU Special National Conditions

As shown in the Test Report Ref. No. which forms part of this Certificate

4351320.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands