

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product LED panel luminaire (suitable for suspension mounted or recessed mounted)

Name and address of the applicant Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven,
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven,
The Netherlands

Name and address of the factory

☐ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

33-41Vdc 1,15A; 38W or 38-47Vdc; 2A; 85W;
Class III; IP40; constant current; Uout: 60Vdc; ta 45°C
(for details see annex model list of test report 6060560.50)

Tra demark (if any)

N/A

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CertaFlux LED Panel 6060 830 MD2
CertaFlux LED Panel 6060 840 MD2
CertaFlux LED Panel 6060 865 MD2
CertaFlux LED Panel 30120 830 MD2
CertaFlux LED Panel 30120 840 MD2
CertaFlux LED Panel 30120 865 MD2
CertaFlux LED Panel 6262 830 MD2
CertaFlux LED Panel 6262 840 MD2
CertaFlux LED Panel 6262 865 MD2
CertaFlux LED Panel 6060 830 UC MD2
CertaFlux LED Panel 6060 840 UC MD2
CertaFlux LED Panel 6060 865 UC MD2
CertaFlux LED Panel 30120 830 UC MD2
CertaFlux LED Panel 30120 840 UC MD2
CertaFlux LED Panel 30120 865 UC MD2
CertaFlux LED Panel 60120 830 MD2
CertaFlux LED Panel 60120 840 MD2
CertaFlux LED Panel 60120 865 MD2
CertaFlux LED Panel 60120 830 UC MD2
CertaFlux LED Panel 60120 840 UC MD2
CertaFlux LED Panel 60120 865 UC MD2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-09-09

Signature: Kate Xu

page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-1:1979, IEC 60598-2-1:1979/AMD1:1987, IEC 60598-2-2:2011

National differences:

EU Group Differences

6060560.50

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-09-09

Signature: Kate Xu



page 2 of 2