

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product LED driver

Name and address of the applicant Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2

Ratings and principal characteristics

XITANIUM 150W 1.0-1.5A 1-10V 220-240V RI132:  
XITANIUM 150W 1.0-1.5A 1-10V 220-240V RI132S:  
Uin: 220-240 VAC; Freq: 50/60 Hz; Iin: 0,72 AAC; PF: >0,95;  
Iout: 1,0-1,5 ADC; Uout: 70-130 VDC, 330 VDC Max.;  
Pout: 150 W; tc: 80 °C; ta: 65 °C; IP65; Independent

XITANIUM 100W 0.7-1.0A 1-10V 220-240V RI132:  
XITANIUM 100W 0.7-1.0A 1-10V 220-240V RI132S:  
Uin: 220-240 VAC; Freq: 50/60 Hz; Iin: 0,5 AAC; PF: >0,95;  
Iout: 0,7-1,0 ADC; Uout: 70-130 VDC, 330 VDC Max.;  
Pout: 100 W; tc: 80 °C; ta: 70 °C; IP65; Independent

XITANIUM 200W 1.4-2.0A 1-10V 220-240V RI132:  
XITANIUM 200W 1.4-2.0A 1-10V 220-240V RI132S:  
Uin: 220-240 VAC; Freq: 50/60 Hz; Iin: 0,97 AAC; PF: >0,95;  
Iout: 1,4-2,0 ADC; Uout: 70-130 VDC, 330 VDC Max.;  
Pout: 200 W; tc: 80 °C; ta: 60 °C; IP65; Independent

Trademark (if any)

**PHILIPS**

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

XITANIUM 150W 1.0-1.5A 1-10V 220-240V RI132  
XITANIUM 150W 1.0-1.5A 1-10V 220-240V RI132S  
XITANIUM 100W 0.7-1.0A 1-10V 220-240V RI132  
XITANIUM 100W 0.7-1.0A 1-10V 220-240V RI132S  
XITANIUM 200W 1.4-2.0A 1-10V 220-240V RI132  
XITANIUM 200W 1.4-2.0A 1-10V 220-240V RI132S

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2020-10-28

Signature: Kate Xu

page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences

6089149.50 and 6089149.51

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

