

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic controlgear for LED modules

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uin: 100-277 V; fn: 50/60 Hz; PF: 0,95;
Iin: 0,25-1,5 A; Irated: 0,9-8,3 Adc; Prated: 65~250 W;
Output Voltage(range): 24-50 Vdc, Uout: 60V dc
ta: -40...+55 °C; Independent; IP67
tc: 90 °C / 85 °C;
(See General product information for explanation and range)

Trademark / Brand (if any)

PHILIPS
PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xi EP LV pW xA-yA WL 1-10V Im
Xi EP LV pW xA-yA WL Im
(See General product information for explanation and range)

Additional information (if necessary may also be reported on page 2)

This certificate replaces NL- 78327 dated on 2021-12-28 due to technical modifications

☐ [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2020

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6154180.50 and 6154180.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-03-21

Signature: Kate Xu

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2023-03-21

Signature: Kate Xu