

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Taiwan Surface Mounting Technology (SuZhou) Co., Ltd. No. 888 Ganquan Dong Road Economic Technology Development Zone Wujiang, 215200 Suzhou China
Ratings and principal characteristics	<p>Xitanium Dim 150W 0.7A 1-10V 230V I175 & Xitanium Dim 150W 0.7A 1-10V 230V I175C: Un: 220-240 VAC; fn: 50/60 Hz; In: 0,6-0,83 Aac; PF: 0,98; Iout: 0,7 Adc; Uout: 96-214 Vdc, 320 Vdc Max.; tc: 80 °C; ta: -40...+55 °C; IP67; independent; separating between input and output</p> <p>Xitanium Dim 150W 1.05A 1-10V 230V I175 & Xitanium Dim 150W 1.05A 1-10V 230V I175C: Un: 220-240 VAC; fn: 50/60 Hz; In: 0,6-0,83 Aac; PF: 0,98; Iout: 1,05 Adc; Uout: 62-142 Vdc, 220 Vdc Max.; tc: 80 °C; ta: -40...+55 °C; IP67; independent; separating between input and output</p> <p>Xitanium Dim 100W 0.7A 1-10V 230V I175 & Xitanium Dim 100W 0.7A 1-10V 230V I175C: Un: 220-240 VAC; fn: 50/60 Hz; In: 0,4-0,56 Aac; PF: 0,95; Iout: 0,7 Adc; Uout: 64-143 Vdc, 220 Vdc Max.; tc: 80 °C; ta: -40...+55 °C; IP67; independent; separating between input and output</p> <p>Xitanium Dim 100W 1.05A 1 10V 230V I175 & Xitanium Dim 100W 1.05A 1-10V 230V I175C: Un: 220-240 VAC; fn: 50/60 Hz; In: 0,4-0,56 Aac; PF: 0,95; Iout: 1,05 Adc; Uout: 42-95 Vdc, 170 Vdc Max.; tc: 80 °C; ta: -40...+55 °C; IP67; independent; separating between input and output</p>
Trademark (if any)	PHILIPS

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium Dim 150W 0.7A 1-10V 230V I175
Xitanium Dim 150W 0.7A 1-10V 230V I175C
Xitanium Dim 150W 1.05A 1-10V 230V I175
Xitanium Dim 150W 1.05A 1-10V 230V I175C
Xitanium Dim 100W 0.7A 1-10V 230V I175
Xitanium Dim 100W 0.7A 1-10V 230V I175C
Xitanium Dim 100W 1.05A 1-10V 230V I175
Xitanium Dim 100W 1.05A 1-10V 230V I175C

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6041857.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-11-19

Signature: Kreny Lin



page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Hengdian Group Tospo Lighting Co., Ltd.
Hengdian Electronics Industrial Zone, Dongyang City, Jinhua, 322118
Zhejiang
China

Dongyang Tospo Lighting Optoelectronic Co., Ltd.
NO.5 NO.8 workshop, NO.88 Kexing Road, Hengdian Dongyang City,
Zhejiang Province
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

