

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Product : LED driver
Trade name(s) : PHILIPS
Type(s)/model(s) : Xitanium Dim 220W 1.05A 1-10V 230V I240 and
Xitanium Dim 220W 1.05A 1-10V 230V I240C

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006, EN 62384:2006/A1:2009, EN 60598-1:2015 and EN 60598-1:2015/A1:2018
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 5 November 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-116249

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED driver
Trade name(s)	: PHILIPS
Type(s)/model(s)	: Xitanium Dim 220W 1.05A 1-10V 230V I240 and Xitanium Dim 220W 1.05A 1-10V 230V I240C
Rated voltage	: 220-240 Vac
Rated frequency	: 50/60 Hz
Rated input current	: 1,3-0,9 Aac
Power factor	: 0,98
Output current	: 1,05 Adc
Output voltage	: 100-210 Vdc; 270 Vdc (max. Open circuit voltage)
Output power	: 220 W
Max. case temperature (tc)	: 85 °C
Ambient temperature range (ta)	: -40...+65 °C
Description	: independent
IP classification	: IP67

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009
EN 60598-1:2015
EN 60598-1:2015/A1:2018

Test result

The test results are laid down in DEKRA test file 608716100.

Additional information

- The insulation between primary and secondary is considered as basic insulation
- Constant current type
- completely potted

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

This certificate replaces certificate No. 31-111811 which we hereby declare invalid.

The list of components is laid down in test report 6087161.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory locations are registered with the numbers 306303, 312989, 1845 and 15204.