

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**
CB TEST CERTIFICATE

Product

Class III Track System

Name and address of the applicant


Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48
Eindhoven, 5656 AE Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2


☐ Additional Information on page 2

Ratings and principal characteristics

24 Vdc Pmax: 100 W Imax: 4,2 A Class III T ambient: 45 °C

Trademark (if any)

PHILIPS

Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

RDL track Lmm C
See Page 2

Additional information (if necessary may also be reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60570:2003/AMD1:2017, IEC 60570:2003, IEC 60598-1:2014/ AMD1:2017, IEC 60598-1:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

4789150407.2 issued on 2019-09-03

This CB Test Certificate is issued by the National Certification Body



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

Date: 2019-09-11

Signature:



Jan-Erik Storgaard

For full legal entity names see www.ul.com/ncbnames

Model Details:
Product Key:
RDL track Lmm C
Where:

- L = Track length in mm (three or four digits, maximum value 1800);
C = Color of Track (one character, may be "gr" or "T")

Additional Information:

Additionally evaluated to EN 60570:2003/A1:2018, EN 60598-1:2015 /A1:2018
National Differences specified in the CB Test Report.

- The Track System shall only be supplied by a separately approved power supply 24 Vdc, constant voltage, SELV and short-circuit proof. Maximum load of the Track System is 100 W (24 V 4,2 A). A single luminaire supply connector can handle maximum load of 48 W (24 V 2 A).
- The Track System (as required by the client) has been also evaluated according to clauses 21.1 and 30.2.1 of IEC/EN 60335-1 standard.

Additional information (if necessary)


UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/nccnames
Date: 2019-09-11

Signature:


Jan-Erik Storgaard