

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product LED driver

Name and address of the applicant Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the factory

☐ Additional information on page 2

Note: When more than one factory, please report on page 2

### Ratings and principal characteristics

- 1) Xi BP 75W 0.2–0.7A S 230V C133 sXt:  
Pin: 84W; Uin: 220-240V; Iin: 0,4-0,34A; fn: 50/60Hz; PF: 0,95;  
Pout: 75W; Uout: 50-150Vdc, 220Vmax (open circuit);  
Iout: 200-700mA; ta: -40...+55°C; tc: 80°C; Built-in; isolating transformer
- 2) Xi BP 75W 0.3–1.0A S 230V C133 sXt:  
Pin: 84W; Uin: 220-240V; Iin: 0,4-0,34A; fn: 50/60Hz; PF: 0,95;  
Pout: 75W; Uout: 35-108Vdc, 150Vmax (open circuit);  
Iout: 300-1050mA; ta: -40...+55°C; tc: 80°C; Built-in; isolating transformer
- 3) Xi BP 110W 0.2–0.7A S 230V C133 sXt:  
Pin: 121W; Uin: 220-240V; Iin: 0,59-0,49A; fn: 50/60Hz; PF: 0,95;  
Pout: 110W; Uout: 70-220Vdc, 300Vmax (open circuit);  
Iout: 200-700mA; ta: -40...+55°C; tc: 85°C; Built-in; isolating transformer
- 4) Xi BP 110W 0.3–1.0A S 230V C133 sXt:  
Pin: 121W; Uin: 220-240V; Iin: 0,59-0,49A; fn: 50/60Hz; PF: 0,95;  
Pout: 110W; Uout: 50-160Vdc, 230Vmax (open circuit);  
Iout: 300-1050mA; ta: -40...+55°C; tc: 85°C; Built-in; isolating transformer

Trademark (if any)

**PHILIPS**

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

- 1) Xi BP 75W 0.2–0.7A S 230V C133 sXt  
2) Xi BP 75W 0.3–1.0A S 230V C133 sXt  
3) Xi BP 110W 0.2–0.7A S 230V C133 sXt  
4) Xi BP 110W 0.3–1.0A S 230V C133 sXt

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2020-08-10

Signature: Kate Xu

page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009

National differences:

EU Group Differences

6079887.50 and 6079887.51

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

