

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Signify Poland Sp. z o.o. ul Przemysłowa 29, 64-920 Pila, Poland
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	<p>Xitanium 60W 0.08-0.35A 300V 16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 60 W; Uout: 100-300 Vdc, 330 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in</p> <p>Xitanium 60W 0.08-0.35A 220V 16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,3 A; Pn: 66 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 60 W; Uout: 50-220 Vdc, 250 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in</p> <p>Xitanium 35W 0.08-0.35A 150V 16 230V: Un: 220-240 V; fn: 50/60 Hz; DC; In: 0,17 A; Pn: 39 W; PF: 0,9C; Iout: 0,08-0,35 A; Pout: 35 W; Uout: 50-150 Vdc, 250 Vdc max; tc: 75 °C; ta: -25...+50 °C; Built-in</p>
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	<p>Xitanium 60W 0.08-0.35A 300V 16 230V</p> <p>Xitanium 60W 0.08-0.35A 220V 16 230V</p> <p>Xitanium 35W 0.08-0.35A 150V 16 230V</p>
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	<p>IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009</p> <p>National differences: EU Group Differences</p>

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-11-20

Signature: Kate Xu



page 1 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No. which
forms part of this Certificate

6064958.50 and 6064958.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-11-20

Signature: Kate Xu

A handwritten signature in black ink, appearing to be 'Kate Xu', is written over the printed signature text.

page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Fideltronik Poland Sp.z.o.o.

ul Beniowskiego 1, 34-200, SUCHA BESKIDZKA,
Poland

Zhejiang Klite Lighting Holdings Co., Ltd.

No.12 TingChao Road, Jianshan New District, 314416 Haining City, Zhejiang
Province,
China

Signify Electronics (Xiamen) Co., Ltd.

No 2000, North Yunding Road, Xiamen,
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-11-20

Signature: Kate Xu

page 3 of 3