



中国国家强制性产品认证证书

证书编号: 2016011002918327

发证日期: 2021年11月09日

有效期至: 2026年11月09日

认证委托人名称 Signify Netherlands B.V.
及注册地址 High Tech Campus 48, 5656 AE Eindhoven, 荷兰

产品生产者名称 Signify Netherlands B.V.
及注册地址 High Tech Campus 48, 5656 AE Eindhoven, 荷兰

生产企业名称 Signify Netherlands B.V.
及生产地址 High Tech Campus 48, 5656 AE Eindhoven, 荷兰

产品名称和系列、规格、型号 LED 模块用交直流电子控制装置(LED控制装置, 内装式, 自耦式, 控制端口调光, 恒流模式, $t_a: 60^{\circ}\text{C}$, $t_c: 90^{\circ}\text{C}$, 定温热保护: 110°C)
见附件。220-240V ~ 50/60Hz; 220-240VDC

产品标准和
技术要求 GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年11月10日

经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发: 谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016011002918327

Valid from: Nov.09,2021

Valid until: Nov.09,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, The Netherlands

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, The Netherlands

**NAME AND LOCATION
OF THE FACTORY**

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven, The Netherlands

PRODUCT MODEL(S)

A.C. or D.C. Supplied Electronic Controlgear For LED Modules (Built-in, Auto-wound Controlgear,
Controlled Port Dimming, Constant Current Mode, ta:60°C, tc:90°C, Temperature Declared Thermally
Protected: 110°C)
See Appendix. 220-240V~ 50/60Hz; 220-240VDC

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.10,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

证书编号: 2016011002918327

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 2956596

型号	输入规格	输入电流	输出电流	输出电压	最大输出电压	输出功率
Xitanium 150W 0.2-0.7A 300V iXt TD 230V	220-240V~, 50/60Hz; 220-240V ===	0.72A	0.2-0.7A	100-300VDC	Max. 330VDC	150W
Xitanium 100W 0.15-0.5A 300V iXt TD 230V	220-240V~, 50/60Hz; 220-240V ===	0.49A	0.15-0.50A	100-300VDC	Max. 330VDC	100W
XI 150W 0.2-0.7A 300V iXt TDCL 230V	220-240V~, 50/60Hz; 220-240V ===	0.72A	0.2-0.7A	100-300VDC	Max. 330VDC	150W
XI 100W 0.15-0.5A 300V iXt TDCL 230V	220-240V~, 50/60Hz; 220-240V ===	0.49A	0.15-0.50A	100-300VDC	Max. 330VDC	100W



中国质量认证中心

