

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic driver for LED modules
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	U _{in} : 220-240 V I _{in} : 0.49 A P _{in} : 107 W f _n : 50/60 Hz; DC PF: 0.9C t _c : 90 °C U _{out} : 100-300 V I _{out} : 0.15-0.50 A U _{out} max: 330 V P _{out} : 100 W t _a : -40...+60 °C
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 100W 0.15-0.5A 300V iXt TD 230V
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009 National differences: EU Group Differences 2230591.50 and 2230591.51
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands




IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory


This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-10-01

Signature: Anouschka Slingerland



page 2 of 2