

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product LED driver

Name and address of the applicant Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the factory

☐ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

- 1) Xi SR 75W 0.2–0.7A SNEMP 230V S240 sXt:  
Pin: 82W; Uin: 220-240V~; Iin: 0,38-0,34A~; fn: 50/60Hz; PF: 0,95;  
Uin: 186-250Vdc; Iin: 0,3-0,04Adc; Pout: 75W; Uout: 50-150Vdc,  
200Vmax; Iout: 200-700mA; Isr: 52-60mA; ta: -40...+55°C;  
tc: 80°C; Built-in
- 2) Xi SR 75W 0.3–1.0A SNEMP 230V S240 sXt:  
Pin: 82W; Uin: 220-240V~; Iin: 0,38-0,34A~; fn: 50/60Hz; PF: 0,95;  
Uin: 186-250Vdc; Iin: 0,3-0,04Adc; Pout: 75W; Uout: 35-108Vdc,  
150Vmax; Iout: 300-1050mA; Isr: 52-60 mA; ta: -40...+55°C;  
tc: 80°C; Built-in
- 3) Xi SR 150W 0.2–0.7A SNEMP 230V S240 sXt:  
Pin: 162W; Uin: 220-240V~; Iin: 0,76-0,67A~; fn: 50/60Hz; PF: 0,95;  
Uin: 186-250Vdc; Iin: 0,6-0,07Adc; Pout: 150W; Uout: 90-283Vdc,  
350Vmax; Iout: 200-700mA; Isr: 52-60mA; ta: -40...+55°C;  
tc: 85°C; Built-in
- 4) Xi SR 150W 0.3–1.0A SNEMP 230V S240 sXt:  
Pin: 162W; Uin: 220-240V~; Iin: 0,76-0,67A~; fn: 50/60Hz; PF: 0,95;  
Uin: 186-250Vdc; Iin: 0,6-0,07Adc; Pout: 150W; Uout: 70-214Vdc,  
260Vmax; Iout: 300-1050mA; Isr: 52-60mA; ta: -40...+55°C;  
tc: 85°C; Built-in

Trademark (if any)

**PHILIPS**

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

 **DEKRA**

Date: 2020-06-04

Signature: Kate Xu

 page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Model / Type Ref.

- 1) Xi SR 75W 0.2–0.7A SNEMP 230V S240 sXt
- 2) Xi SR 75W 0.3–1.0A SNEMP 230V S240 sXt
- 3) Xi SR 150W 0.2–0.7A SNEMP 230V S240 sXt
- 4) Xi SR 150W 0.3–1.0A SNEMP 230V S240 sXt

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6073237.50 and 6073237.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

Date: 2020-06-04

Signature: Kate Xu



page 2 of 2