

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

LED drivers

Name and address of the applicant

Philips Lighting B.V.  
High Tech Campus 48  
5656 AE Eindhoven  
The Netherlands

Name and address of the manufacturer

Philips Lighting B.V.  
High Tech Campus 48  
5656 AE Eindhoven  
The Netherlands

Name and address of the factory

☐ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Pn: 42 W, Un: 220-240 V, In: 0,2 A, fn: 50/60 Hz; DC, PF: 0,9C  
Pout: 36 W, Uout: 27-54 Vdc, Iout: 0,3-1,0 A max., tc: 75 °C,  
ta: -20...+50 °C, Uout max = 60 Vdc

Trademark (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Xitanium 36W 0.3-1.0A 54V SR 230V  
Xitanium 36W 0.3-1.0A 54V TD 230V

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

2233217.52 and 2233217.53

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-01-17

Signature: Anouschka Slingerland



page 1 of 1