



中国国家强制性产品认证证书

证书编号: 2020011002292318

委托人名称、地址

昕诺飞(中国)投资有限公司
上海市闵行区田林路 888 弄 9 号楼

生产者(制造商)名称、地址

昕诺飞(中国)投资有限公司
上海市闵行区田林路 888 弄 9 号楼

生产企业名称、地址

产品名称和系列、规格、型号

LED 模块用交直流电子控制装置(LED 控制装置, 内装式, 自耦式, 恒流模式, $t_a: 50^{\circ}\text{C}$, $t_c: 75^{\circ}\text{C}$, 定温热保护: 110°C , 不可调光)

见附件; 输入: 220-240V~ 50/60Hz; 186-250VDC

产品标准和技术要求

GB17625.1-2012; GB/T17743-2017; GB19510.1-2009; GB19510.14-200

9

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求,
特发此证。

发证日期: 2020 年 05 月 14 日有效期至: 2025 年 05 月 14 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P




主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2020011002292318

NAME AND ADDRESS OF THE APPLICANT

Signify (China) Investment Co., Ltd.

Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

NAME AND ADDRESS OF THE MANUFACTURER

Signify (China) Investment Co., Ltd.

Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

NAME AND ADDRESS OF THE FACTORY

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. or D.C. Supplied Electronic Controlgear For LED Modules (Built-in,
Auto-wound Controlgear, Constant Current Mode, ta:50°C, tc:75°C, Temperature
Declared Thermally Protected: 110°C, Non-Dimmable)

See Appendix; Input: 220-240V~ 50/60Hz; 186-250VDC

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: May.14,2020 Valid until:May.14,2025

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn


Accredited by China National Accreditation Service for Conformity Assessment CNAS C0019



President:

陆梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 2595553



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2020011002292318

纸 号: 2595553

序号	型号	输入	输出电流(A)	输出电压 (Vdc)	最大输出电 压 (Vdc)	输出功率
1	Xitanium 60W 0.3/0.35A 85-170V DS 230V	220-240V~ 50/60Hz 0.28A	0.3/0.35A	85-170	250	51/60W
		186-250VDC 0.25-0.35A				
2	Xitanium 50W 0.2/0.25A 100-200V DS 230V	220-240V~ 50/60Hz 0.24A	0.2/0.25A	100-200	250	40/50W
		186-250VDC 0.21-0.3A				
3	Xitanium 30W 0.2/0.25A 60-120V DS 230V	220-240V~ 50/60Hz 0.15A	0.2/0.25A	60-120	200	24/30W
		186-250VDC 0.13-0.18A				

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心