



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA200939

**Certificate Holder:** Signify Netherlands B.V.  
High Tech Campus 48,  
5656 AE Eindhoven,  
Netherlands

**Regulatory Definition:** Non-Prescribed  
**Product Description:** LED driver (Built in, auto-wound, constant current)  
**Trade Name:** PHILIPS  
**Model No.:** Xitanium 60W 0.3/0.35A 85-170V DS 230V  
**Markings:** Input: 220-240Vac 50/60Hz 0.28A; or  
186-250Vdc 0.25-0.35A  
Output: 85-170Vdc 0.3-0.35A, 250Vdc Max, 51-60W  
ta:50°C tc:75°C

**Standard:** AS 61347.2.13:2018

**Conditions:** AS/NZS 61347.1:2016 Inc A1  
All models approved under this Certificate  
must comply with the Standard requirements  
of the end product when installed.

**Certification Mark:** RCM and SAA200939

**Date First Registered:** 14 May 2020

**Date of Expiry:** 14 May 2025

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 14-05-20 200939/1

[www.jas-anz.org/register](http://www.jas-anz.org/register)



APPROVALS®

## Certificate of Suitability

### \*Addendum\*

**Certificate No.:** SAA200939

**Date of Issue:** 14 May 2020

**Regulatory Definition:** Non-Prescribed

**Product Description:** LED driver (Built in, auto-wound, constant current)

**Additional Models**

**Trade Name**

**Rating**

Xitanium 50W 0.2/0.25A 100-200V DS 230V

PHILIPS

Input: 220-240Vac 50/60Hz 0.24A; or  
186-250Vdc 0.21-0.3A

Output: 100-200Vdc 0.2-0.25A, 250Vdc Max, 40-50W

Xitanium 30W 0.2/0.25A 60-120V DS 230V

PHILIPS

Input: 220-240Vac 50/60Hz 0.15A; or  
186-250Vdc 0.13-0.18A

Output: 60-120Vdc 0.2-0.25A, 200Vdc Max, 24-30W

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 14-05-20 200939/2

[www.jas-anz.org/register](http://www.jas-anz.org/register)