

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Product : EasyAir Fixture-Mount
Trade name(s) : PHILIPS
Type(s)/model(s) : SNSX0Z/b, SNSX0Z/g, SNSX0Z/w and SNSX0ZCMP/w

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-11:2001, EN 61347-2-11:2001/C1:2002 and EN 61347-2-11:2001/A1:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 13 November 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-105541 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



S. Lehner
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: EasyAir Fixture-Mount
Trade name(s)	: PHILIPS
Type(s)/model(s)	: SNSX0Z/b, SNSX0Z/g, SNSX0Z/w and SNSX0ZCMP/w
Input voltage/nature of supply	: 16-22 Vdc
Max. case temperature	: tc = 55 °C
Ambient temperature ranges	: ta = 0...+55 °C

Product data – type SNSX0Z/b, SNSX0Z/g and SNSX0Z/w

Description	: built-in
-------------	------------

Product data – type SNSX0ZCMP/w

Description	: independent use
-------------	-------------------

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-11:2001
EN 61347-2-11:2001/C1:2002
EN 61347-2-11:2001/A1:2019

Test result

The test results are laid down in DEKRA test file 224131900.

Additional information

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

This certificate replaces certificate No. 71-105541 which we herewith declare invalid.

The list of components is laid down at test report 2241319.50.

Conclusion

The examination proved that all requirements were met.

Explanation of product key:

SNSX0Z/w, SNSX0Z/g, SNSX0Z/b and SNSX0ZCMP/w

SNS = Product name

X	Function
1	Stand alone
2	Advanced grouping
3	Networked
4	Sensic /C4m

0	IR vertical link
---	------------------

Z	Function
0	Basic
1	Customer specific features
2	ZigBee switch function

CMP = indicated as independent type
 /w; /g; /b = colour of the enclosure
 w = White
 g = Gray
 b = Black

X0Y can be between 100 and 909