

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Electronic driver for LED modules
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Fideltronik Poland Sp.Z o.o. ul. Beniowskiego 1 34-200 Sucha Beskidzka Poland
Ratings and principal characteristics	Xi SR 40W 0.2-0.7A SNEMP 230V C133 sXt Un: 220 - 240 V, In: 0.23 - 0.12 A, Pn: 49 W fn: 50/60 Hz; DC, PF: 0.95, ta: -40...+55 °C tc max: 85 °C, Uout max: 100 V Uout: 25 - 77 Vdc, Iout: 200 - 700 mA, Pout.: 40 W  Xi SR 40W 0.3-1.0A SNEMP 230V C133 sXt Un: 220 - 240 V, In: 0.23 - 0.12 A, Pn: 49 W fn: 50/60 Hz; DC, PF: 0.95, ta: -40...+55 °C tc max: 85 °C, Uout max: 90 V Uout: 20 - 54 Vdc, Iout: 300 - 1050 mA, Pout.: 40 W
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xi SR 40W 0.2-0.7A SNEMP 230V C133 sXt Xi SR 40W 0.3-1.0A SNEMP 230V C133 sXt
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009  National differences: EU Group Differences, AS, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	2220052.50 and 2220052.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands


