

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Ratings and principal characteristics	Input: 220-240 V, 50/60 Hz, 0,07-0,2 A, $\lambda=0,9-0,94$ C 186-250 V, 0 Hz, 0,08-0,22 Output: 0,5-1,05 A, 12-40 W, UOUT=60 Vdc
Trademark (if any)	Philips Lighting or PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xitanium 12W 0,08-0,5A 24V 230V, Xitanium 23W 0,15-0,7A 38V 230V, Xitanium 20W R 0,15-0,5A 54V TD/I, Xitanium 40W R 0,3-1,05A 54V TD/I
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 See Dekra CB report No.2102919.50 for complete electrical ratings
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	2102919.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, NetherlandsFirmat digitalmente da
MASSIMILIANO TRIULZI