

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	Un: 220-240 Vac, 186-250 Vdc; fn: 50/60 Hz; PF: 0,9C; Pn: 42W; In: 0,2 Aac, 0,23-0,16 Adc; U-OUT: 60 Vdc max; I-OUT: 1,05 Adc; P-OUT: 36 W; tc: +85 °C; ta: -25...+50 °C; SELV; Built-in or Independent (with SR cover)
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	XITANIUM 36W/m 0.15-1.05A 48V MC 230V
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009 National differences: EU Group Differences 6071722.50 and 6071722.51
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2020-03-25

Signature: Kate Xu

A handwritten signature in black ink, appearing to read 'Kate Xu', is written over the printed name.

page 2 of 2