



APPROVALS®

Certificate of Suitability

Certificate No.: SAA203437

Certificate Holder: Signify Netherlands B.V.
High Tech Campus 48,
5656 AE Eindhoven,
Netherlands

Regulatory Definition: Non-Prescribed
Product Description: LED Driver
Trade Name/s: PHILIPS
Model No.: Xitanium 90W 0.25-0.7A 220V TD21 230V
Rating/Marking/s: Uin: 220-240Vac / 186-250Vdc, Iin: 0.44Aac / 0.52Adc,
Pn: 97W; 50/60Hz or DC
Uout max: 250Vdc, Uout: 50-220Vdc, Iout: 0.25-0.7Adc,
Pout: 90W
pf: 0.9C, tc: 75°C, ta: -25°C to +50°C

Standard/s: AS 61347.2.13:2018

Condition/s: AS/NZS 61347.1:2016 Inc A1
Must comply with standard requirements of
end-product when installed.

Approval Marks: RCM and SAA203437

Initial Issue Date: 28 January 2021

Expiry Date: 28 January 2026

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 28-01-21 203437/1



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA203437

Date of Issue: 28 January 2021

Regulatory Definition: Non-Prescribed

Product Description: LED Driver

Additional Models	Trade Name	Rating/Marking
Xitanium 90W 0.25-0.7A 220V S TD21 230V	PHILIPS	Uin: 220-240Vac / 186-250Vdc, Iin: 0.44Aac / 0.52Adc, Pn: 97W; 50/60Hz or DC Uout max: 250Vdc, Uout: 50-220Vdc, Iout: 0.25-0.7Adc, Pout: 90W pf: 0.9C, tc:75°C, ta:-25°C to +50°C
Xitanium 90W 0.15-0.5A 300V TD21 S 230V	PHILIPS	Uin: 220-240Vac / 186-250Vdc, Iin: 0.44Aac / 0.52Adc, Pn: 97W; 50/60Hz or DC Uout max: 330Vdc, Uout: 100-300Vdc, Iout: 0.15-0.5Adc, Pout: 90W pf: 0.9C, tc:75°C, ta:-25°C to +50°C

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 28-01-21 203437/2

www.jas-anz.org/register