

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product LED driver

Name and address of the applicant Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven,  
The Netherlands

Name and address of the factory

☒ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Xitanium 20W/a 0.15-0.5A 42V 3CW 230V:  
Xitanium 20W/a 0.15-0.5A 42V 3CB 230V:  
Xitanium 20W/a 0.15-0.5A 42V 3CG 230V:  
Un: 220-240 V~; fn: 50/60 Hz; In: 0,12 A~; Pn: 25 W; PF: 0,9C;  
Iout: 0,15-0,5 A; Pout: 20 W; Uout: 10-42 Vdc, 60 Vdcmax;  
tc: 85 °C; ta: -20...+35 °C; SELV; Independent

Xitanium 42W/a 0.3-1.05A 42V 3CW 230V:  
Xitanium 42W/a 0.3-1.05A 42V 3CB 230V:  
Xitanium 42W/a 0.3-1.05A 42V 3CG 230V:  
Un: 220-240 V~; fn: 50/60 Hz; In: 0,25 A~; Pn: 50 W; PF: 0,9C;  
Iout: 0,3-1,05 A; Pout: 42 W; Uout: 10-42 Vdc, 60 Vdcmax;  
tc: 85 °C; ta: -20...+35 °C; SELV; Independent

Trademark (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Xitanium 20W/a 0.15-0.5A 42V 3CW 230V  
Xitanium 20W/a 0.15-0.5A 42V 3CB 230V  
Xitanium 20W/a 0.15-0.5A 42V 3CG 230V  
Xitanium 42W/a 0.3-1.05A 42V 3CW 230V  
Xitanium 42W/a 0.3-1.05A 42V 3CB 230V  
Xitanium 42W/a 0.3-1.05A 42V 3CG 230V

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-12-19

Signature: Kate Xu

page 1 of 3

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

A sample of the product was tested and found  
to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-  
1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC  
62384:2006/AMD1:2009

National differences:

EU Group Differences

6066727.50 and 6066727.51

As shown in the Test Report Ref. No. which  
forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-12-19

Signature: Kate Xu



page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-12-19

Signature: Kate Xu

A handwritten signature in black ink, appearing to read 'Kate Xu', is written over a horizontal line.

page 3 of 3