

CERTIFICATE

Issued to:
Applicant:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Licensee:
Signify Netherlands B.V.
High Tech Campus 48
5656 AE Eindhoven, The Netherlands

Product : Electronic driver for LED modules
Trade name(s) : PHILIPS
Type(s)/model(s) : Xitanium 35W 0.08-0.35A 220V TD21 230V,
Xitanium 60W 0.08-0.35A 300V TD21CL 230V,
Xitanium 60W 0.08-0.35A 300V TD21 230V and
Xitanium 60W 0.15-0.5A 220V TD21 230V

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947556


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 17 February 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-108235 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic driver for LED modules
Trade name(s)	: PHILIPS
Type(s)/model(s)	: Xitanium 35W 0.08-0.35A 220V TD21 230V, Xitanium 60W 0.08-0.35A 300V TD21CL 230V, Xitanium 60W 0.08-0.35A 300V TD21 230V and Xitanium 60W 0.15-0.5A 220V TD21 230V
Rated voltage/nature of supply	: 220-240 Vac/dc
Rated frequency	: 50/60 Hz; DC
Ambient temperature range	: ta: -25... +50 °C
Maximum case temperature	: tc: 75 °C
Power factor	: pf: 0.9C
Description	: built-in LED drivers

Product data – type Xitanium 35W 0.08-0.35A 220V TD21 230V

Rated input current (Iin)	: 0.18 A
Rated input power (Pin)	: 39 W
Output voltage range (Uout)	: 50-220 Vdc
Open circuit voltage (Uout max)	: 250 V
Output current range (Iout)	: 0.08-0.35 Adc
Output power (Pout)	: 35 W

**Product data – type Xitanium 60W 0.08-0.35A 300V TD21 230V and
Xitanium 60W 0.08-0.35A 300V TD21CL 230V**

Rated input current (Iin)	: 0.30 A
Rated input power (Pin)	: 66 W
Output voltage range (Uout)	: 100-300 Vdc
Open circuit voltage (Uout max)	: 330 V
Output current range (Iout)	: 0.08-0.35 Adc
Output power (Pout)	: 60 W

Product data – type Xitanium 60W 0.15-0.5A 220V TD21 230V

Rated input current (Iin)	: 0.30 A
Rated input power (Pin)	: 66 W
Output voltage range (Uout)	: 50-220 Vdc
Open circuit voltage (Uout max)	: 250 V
Output current range (Iout)	: 0.15-0.5 Adc
Output power (Pout)	: 60 W

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009

Test result

The test results are laid down in DEKRA test file 225352100.

Additional information

The insulation between In/output to Metal enclosure/PE: Basic insulation

The insulation between In/output to DALI: Basic insulation

The insulation between DALI to Metal enclosure/PE: Basic insulation

- Temperature declared thermally protected: 110 °C
- Suitable for emergency luminaire acc. IEC 60598-2-22, excluding high risk task areas

This certificate replaces certificate No. 71-108235 which we hereby declare invalid.

The list of components is laid down in test report 2253521.50.

Conclusion

The examination proved that all requirements were met.