


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	LED drivers
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Fideltronik Poland Sp.z.o.o. ul Beniowskiego 1, 34-200, SUCHA BESKIDZKA, Poland
Ratings and principal characteristics	Xi LP 22W 0.2-0.7A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; lin: 0,12-0,11A; Pin: 26W; PF: 0,95; Uout: 16-48Vdc; Uout (open circuit)=70 Vdc; Iout: 200-700 mA; Pout: 22W; ta: -40..+55° C; tc: 85 °C; SELV  Xi LP 22W 0.3-1.0A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; lin: 0,12-0,11A; Pin: 26W; PF: 0,95; Uout: 8-32Vdc; Uout (open circuit)=50 Vdc; Iout: 300-1050mA; Pout: 22W; ta: -40..+55°C; tc: 85 °C; SELV  Xi LP 40W 0.2-0.7A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; lin: 0,21-0,19A; Pin: 46W; PF: 0,95; Uout: 25-77Vdc; Uout (open circuit)=100 Vdc; Iout: 200-700mA; Pout: 40W; ta: -40..+55° C; tc: 85 °C; SELV  Xi LP 40W 0.3-1.0A S1 230V C123 sXt: Un: 220-240V; fn: 50/60 Hz; lin: 0,21-0,19A; Pin: 46W; PF: 0,95; Uout: 20-54Vdc; Uout (open circuit)=60 Vdc; Iout: 300-1050mA; Pout: 40W; ta: -40..+55° C; tc: 85 °C; SELV
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xi LP 22W 0.2-0.7A S1 230V C123 sXt Xi LP 22W 0.3-1.0A S1 230V C123 sXt Xi LP 40W 0.2-0.7A S1 230V C123 sXt Xi LP 40W 0.3-1.0A S1 230V C123 sXt
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands  
Signature: Kate Xu

Date: 2019-07-26

page 1 of 2

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

A sample of the product was tested and found  
to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC  
62384:2006/AMD1:2009

National differences:

EU Group Differences

6059836.50 and 6059836.51

As shown in the Test Report Ref. No. which  
forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

