



中国国家强制性产品认证证书

证书编号: 2017011002992644

发证日期: 2021年03月12日

有效期至: 2022年08月10日

认证委托人名称 昕诺飞(中国)投资有限公司
及注册地址 上海市闵行区田林路888弄9号楼

产品生产者名称 昕诺飞(中国)投资有限公司
及注册地址 上海市闵行区田林路888弄9号楼

生产企业名称
及生产地址

产品名称和系列、
规格、型号

LED 模块用交直流电子控制装置(LED 控制装置, 内装式, 控制端口调光, 恒流模式, $t_a: 55^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$,
定温热保护: 130°C)
Xi FP 75W 0.2-0.7A SNLDAE 230V C133 sXt 输出: 0.2-0.7A, 50-150Vdc, Max.220Vdc, 75W;
Xi FP 75W 0.3-1.0A SNLDAE 230V C133 sXt 输出: 0.3-1.05A, 35-108Vdc, Max.150Vdc, 75W。
输入: 220-240V ~ 50/60Hz; 186-250Vdc

GB 17625.1-2012;GB/T 17743-2017;GB 19510.1-2009;GB 19510.14-2009

产品标准和
技术要求

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书为变更证书, 证书首次颁发日期: 2017年08月10日
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

陆梅

中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017011002992644

Valid from: Mar.12,2021

Valid until: Aug.10,2022

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Signify (China) Investment Co., Ltd.
Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Signify (China) Investment Co., Ltd.
Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

**NAME AND LOCATION
OF THE FACTORY**

Signify (China) Investment Co., Ltd.
Building no.9, Lane 888, Tianlin Road, Minhang District, Shanghai 200233, China

PRODUCT MODEL(S)

A.C. or D.C. Supplied Electronic Controlgear For LED Modules(Built-in, Controlled Port Dimming,
Constant Current Mode, ta:55°C, tc:80°C, Temperature Declared Thermally Protected: 130°C)
Xi FP 75W 0.2-0.7A SNLDAE 230V C133 sXt Output: 0.2-0.7A, 50-150Vdc, Max.220Vdc, 75W; Xi FP
75W 0.3-1.0A SNLDAE 230V C133 sXt Output: 0.3-1.05A, 35-108Vdc, Max.150Vdc, 75W. Input:
220-240V~ 50/60Hz; 186-250Vdc

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2017;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.10,2017

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA' s website: www.cnca.gov.cn



SIGNATURE:

陆梅

CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2017011002992644

申请编号 Application No. : A2021CCC1002-3665960

申请人(委托人) Applicant: 昕诺飞(中国)投资有限公司 / Signify (China) Investment Co., Ltd.

证书编号 Certificate No.(变更前 Original): 2017011002992644

变更产品名称: LED 模块用交直流电子控制装置(LED 控制装置, 内装式, 控制端口调光, 恒流模式, $t_a: 55^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$, 定温热保护: 130°C)

Name of Product Modified: A.C. or D.C. Supplied Electronic Controlgear For LED Modules(Built-in, Controlled Port Dimming, Constant Current Mode, $t_a: 55^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$, Temperature Declared Thermally Protected: 130°C)

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	EMC 标准换版	GB/T17743-2007	GB/T 17743-2017
2	勘误证书上产品名称	LED 模块用交流电子控制装置(LED 控制装置, 内装式, 可调光, 恒流模式, $t_a: 55^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$, 定温热保护: 130°C)	LED 模块用交直流电子控制装置(LED 控制装置, 内装式, 控制端口调光, 恒流模式, $t_a: 55^{\circ}\text{C}$, $t_c: 80^{\circ}\text{C}$, 定温热保护: 130°C)
3	勘误证书上产品输入规格	输入: 220-240V~ 50/60Hz	输入: 220-240V~ 50/60Hz; 186-250Vdc
4	增加新的铭牌样式	见原报告: C-00201-17-1221	见本次变更报告: C-00201-21M-0273
5	变更关键件	见原报告: C-00201-17-1221	见本次变更报告: C-00201-21M-0273

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期(Date): 2021 年 03 月 12 日

第 1 页 / 共 1 页



中国质量认证中心