

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED driver

Name and address of the applicant

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven,
The Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven,
The Netherlands

Name and address of the factory

☒ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Xi FP 75W 0.2-0.7A SNLDAE 230V C133 sXt:
Uin: 220-240 Vac; fn: 50/60 Hz; lin: 0,4-0,34 Aac; Pin: 84 W;
Uin: 186-250 Vdc; lin: 0,48 Adc max; PF: 0,95;
Iout: 200-700 mA; Pout: 75 W; Uout: 50-150 Vdc, 220 Vmax;
ta: -40...+55 °C; tc: 80 °C; Built-in; isolatingXi FP 75W 0.3-1.0A SNLDAE 230V C133 sXt:
Uin: 220-240 Vac; fn: 50/60 Hz; lin: 0,4-0,34 Aac; Pin: 84 W;
Uin: 186-250 Vdc; lin: 0,48 Adc max; PF: 0,95;
Iout: 300-1050 mA; Pout: 75 W; Uout: 35-108 Vdc, 150 Vmax;
ta: -40...+55 °C; tc: 80 °C; Built-in; isolatingXi FP 75W .3-1A SNLDAE 230 C133 TR sXt:
Uin: 220-240 Vac; fn: 50/60 Hz; lin: 0,4-0,34 Aac; Pin: 84 W; PF: 0,95;
Iout: 300-1050 mA; Pout: 75 W; Uout: 35-108 Vdc, 150 Vmax;
ta: -40...+55 °C; tc: 80 °C; Built-in; isolatingXi FP 75W 0.5-1.5A SNLDAE 230V C133 sXt:
Uin: 220-240 Vac; fn: 50/60 Hz; lin: 0,4-0,34 Aac; Pin: 84 W;
Uin: 186-250 Vdc; lin: 0,48 Adc max; PF: 0,95;
Iout: 500-1500 mA; Pout: 75 W; Uout: 25-71 Vdc, 120 Vmax;
ta: -40...+55 °C; tc: 80 °C; Built-in; SELV

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Model / Type Ref.

Xi FP 75W 0.2-0.7A SNLDAE 230V C133 sXt
Xi FP 75W 0.3-1.0A SNLDAE 230V C133 sXt
Xi FP 75W .3-1A SNLDAE 230 C133 TR sXt
Xi FP 75W 0.5-1.5A SNLDAE 230V C133 sXt

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This certificate replaces NL-67121 dated on 2020-07-27 due to technical modification.

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6097011.50 and 6097011.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2021-04-06

Signature: Kate Xu



page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2021-04-06

Signature: Kate Xu

