

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product LED driver

Name and address of the applicant Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
The Netherlands

Name and address of the manufacturer Signify Netherlands B.V.
High Tech Campus 48, 5656 AE Eindhoven
The Netherlands

Name and address of the factory ☒ Additional information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

1) XITANIUM 20W/m 0.15-0.5A 54V 230V
Uin: 220-240 Vac, 186-250 Vdc; Freq: 50/60 Hz; DC; lin: 0,12 Aac,
0,13-0,09 Adc; PF: 0,9C; Pin: 24W;
Iout: 0,5 Adc; Pout: 20 W; U-out: 60 Vdc max; tc: 80 °C;
ta: -20...+50 °C; SELV; Built-in or Independent (with SR caps);

2) XITANIUM 36W/m 0.3-1.05A 54V 230V
Uin: 220-240 Vac, 186-250 Vdc; Freq: 50/60 Hz; DC; lin: 0,2 Aac,
0,23-0,16 Adc; PF: 0,9C; Pin: 42W;
Iout: 1,05 Adc; Pout: 36 W; U-out: 60 Vdc max; tc: 80 °C;
ta: -20...+50 °C; SELV; Built-in or Independent (with SR caps);

3) XITANIUM 43W/m 0.7-1.2A 54V 230V
Uin: 220-240 Vac, 186-250 Vdc; Freq: 50/60 Hz; DC; lin: 0,23 Aac,
0,27-0,19 Adc; PF: 0,9C; Pin: 50W;
Iout: 1,2 Adc; Pout: 43 W; U-out: 60 Vdc max; tc: 90 °C;
ta: -20...+45 °C; SELV; Built-in; Independent (with SR caps)

Trademark (if any) PHILIPS

Customer's Testing Facility (CTF) Stage used CTF Stage 3

Model / Type Ref.

1) XITANIUM 20W/m 0.15-0.5A 54V 230V
2) XITANIUM 36W/m 0.3-1.05A 54V 230V
3) XITANIUM 43W/m 0.7-1.2A 54V 230V

Additional information (if necessary may also be reported on page 2) ☐ Additional information on page 2

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-02-22

Signature: Kreny Lin



page 1 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

A sample of the product was tested and found
to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-2-13:2014, IEC
61347-2-13:2014/AMD1:2016

National differences:
EU Group Differences

6044248.50

As shown in the Test Report Ref. No. which
forms part of this Certificate


This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-02-22

Signature: Kreny Lin



page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2019-02-22

Signature: Kreny Lin

A handwritten signature in black ink, appearing to read "Kreny Lin", is written over a faint, circular, light blue watermark that contains the word "DEKRA".