

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48 5656 AE Eindhoven The Netherlands
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 [REDACTED] [REDACTED] [REDACTED] [REDACTED]
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Input: 220-240 V, 50/60 Hz, I <sub>max</sub> =0,11-0,2 A, λ=0,9 C Output: 0,5-1,05 A, 20-36 W, U <sub>OUT</sub> =60 Vdc
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	XITANIUM (series)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 See Dekra CB report No.2102797.50 for complete list of models/types and electrical ratings
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016  Comments: This certificate replaces CB Certificate NL-55347/A1. This Certificate covers also the change of Applicant and Manufacturer name from Philips Lighting B.V. to Signify Netherlands B.V.
As shown in the Test Report Ref. No. which forms part of this Certificate	2102797.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, NetherlandsFirmato digitalmente da  
MASSIMILIANO TRIULZI 